

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1574:134

Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** ADT Security Services, Inc, 695 US Highway 46, Suite 200, Fairfield NJ 07004-1561  
Contact: Ron Dalton (310) 725-2472 FAX (310) 725-2942

**DESIGN:** Model ADT-3203 electric combination rate compensated, fixed temperature, and rate of rise heat detector. Unit intended for use with Simplex Models 4098-9789, -9791 or -9792 detector bases (CSFM Listing No. 7300-0026:217). Refer to listee's printed data sheet for additional detailed product description and operational considerations.

**RATING:** 135°F and 155°F

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, temperature ratings, and UL label.

**APPROVAL:** Listed as a heat detector for use with separately listed Simplex 4100, 4010, 4020 and 4120 series fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**XLf:** 7270-0026:216

02-13-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 13, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**